

**I Airborne sound insulation**

Technical report no.:	08.2005.13
Test institute:	Nüsing
Client:	SOLARLUX Aluminium Systeme GmbH Gewerbepark 9-11 49143 Bissendorf
Product/Component	Five-panel slide and turn balcony glazing
Designation	SL 25R
Exterior dimensions (W x H)	4035 mm x 1530 mm
(Frame) Material	Aluminium extruded profiles
Airborne sound insulation index	<b><math>R'_w = 25 \text{ dB}</math></b>
Special features	Glazing system 8 mm single pane safety glass

The complete test report is available on request.

